

#10

ROUGH IN HVAC

Permit #

Date:

Address:

Contractor:

COPY RIGHTS VILLAGE OF FOUR SEASONS

REVISED SEPTEMBER 2012

Building inspection verification points to comply with 2012 IRC

1. Duct system in crawl space or attic areas must be insulated and all joints tape per M1601.4.5

Code compliant <> Non-Compliant <>

2. Duct location and placement per M1601.4.3

Support of ducts per M1601.4.3

Code compliant <> Non-Compliant <>

3. All mechanical equipment in attic areas requires second safety condensation pans with discharge to daylight per M1411.3.1.

Code compliant <> Non-Compliant <>

4. Mechanical rooms need to have one hour fire rating with fire and smoke detector integrated in to house system.

Code compliant <> Non-Compliant <>

5. Clothes Dryer exhaust per M1502

Code compliant <> Non-Compliant <>

6. Range Hoods exhaust per M1503

Code compliant <> Non-Compliant <>

7. Over Head Exhaust Hoods per M1505

Code compliant <> Non-Compliant <>

8. Mechanical ventilation in Bathroom and toilet rooms per M1507

Code compliant <> Non-Compliant <>

9. Under floor ventilation per R408.1 thru R408.3

Code compliant <> *Non-Compliant* <>

10. Ducts system insulation per Section N1103, N1103.2.1 and N1103.2.2 thru N1103.4.2
and per M1601.3

Code compliant <> *Non-Compliant* <>

Approved <> Date: Inspector: