

# #13

## WALL COVERING

Permit #

Date:

Address:

Contractor:

## COPY RIGHTS VILLAGE OF FOUR SEASONS

### REVISED SEPTEMBER 2012

Building verification points to comply with 2012 IRC

1. Gypsum minimum thickness  $\frac{1}{2}$  on all nailing without adhesive per Table R702.3.5

Code compliant <> Non-Compliant <>

2. With adhesive per Table R702.3.5

Code compliant <> Non-Compliant <>

3. X gypsum on garage ceiling beneath habitable rooms, walls adjoining habitable rooms from garage.

Per Table R702.3.5 note "e"

Code compliant <> Non-Compliant <>

4. Garages and carports protection per section E309 ATTIC ACCESS DOOR AND TRIM AROUND DOOR TO HAVE ONE HOUR FIRE RATEING, ATTIC STAIRS NEEDS TO BE 1 HR RATED.(06-06-2011)

Code compliant <> Non-Compliant <>

5. Under stair protection per R302.7

Code compliant <> Non-Compliant <>

6. Water resistant gypsum per R702.3.8

Code compliant <> Non-Compliant <>

7. Mechanical room will have a one hour fire rated enclosure as per Village Ordinance (09-22-09)

Code compliant <> Non-Compliant <>

Comments \_\_\_\_\_

Approved for tape and bedding placement <>

Inspector:

Date:

