

#16

ROOF STRUCTURAL INSPECTION

Permit #

Date:

Address:

Contractor:

COPY RIGHTS VILLAGE OF FOUR SEASONS

REVISED SEPTEMBER 2012

Building inspection verification points to comply with 2012 IRC

1. The structural roof components shall be capable of supporting the roof covering system and the material and equipment loads that will be encountered during installation of the roof covering system per R907.2

Code compliant <>

Non-Compliant <>

2. Rafter or beam spacing equal to 19 3/16" but not greater than 40" will be lumber or panel sheathed with a minimum of 5/8 inch thickness per VFS Ordinance 09-03.

Compliant <>

Non-Compliant <>

Comments _____

Approved for new shingles placement <>

Inspector:

Date: