

# SWIMMING POOLS

NON

COMPLIANT COMPLIANT

- 1---POOL LOCATION MUST MEET SETBACK REQUIREMENTS.....<>.....<>
- 2...POOL LOCATION MUST NOT HAVE OVERHEAD WIRES.....<>.....<>
- 3...POOL LOCATION MUST NOT BE PLACED WITHIN THE 10,000 SQ. FT. AREA RESERVED FOR  
SEPTIC TANK SYSTEM REPAIR ALSO A SAFE DISTANCE FROM WATER & ELECTRIC LINES...<>.....<>
- 4...REINFORCING STEEL MUST BE IN PLACE & PROPERLY TIED.....<>.....<>
- 5...# 8 COPPER WIRE BONDING, (LIGHTING, LADDERS, HANDHOLDS,PUMP MOTOR) .....<>.....<>
- 6...UNDERGROUND PLUMBING MUST HAVE WATER SUPPLY BACKFLO PREVENTION.....<>.....<>
- 7...UNDERGROUND ELECTRIC MUST BE 12 INCHES BELOW GRADE.....<>.....<>
- 8...NO ELECTRIC RECEPTICLES WITHIN 5 FEET OF POOL.....<>.....<>
- 9...AT LEAST ONE GCFI RECEPTICAL LOCATED 10 TO 20 FOOT FROM POOL, (IN USE COVERS)<>.....<>
- 10...POOL PUMP MUST BE THREE FOOT FROM POOL & GCFI PROTECTED.....<>.....<>
- 11---ALL UNDERGROUND CONDUIT MUST BE 12 INCHES BELOW GRADE.....<>.....<>
- 12...BARRIERS GATES AND ALARMS INSTALLED.....<>.....<>
- 13... CIRCULATION AND FILTER SYSTEMS MUST BE WORKING.....<>.....<>
- 14...DECKS MUST BE SLIP RESISTANT.....<>.....<>

DATE\_\_\_\_\_INSPECTOR\_\_\_\_\_