

#6

UNDERGROUND UTILITIES

Permit #

Date:

Address:

Contractor:

COPY RIGHTS VILLAGE OF FOUR SEASONS

REVISED SEPTEMBER 2012

Building inspection verification points to comply with 2012 IRC and 2008 NEC codes.

1. Trench depth of 28" with 4" depth of clean bedding crushed stone per P2604.1 and warning placement per E3803.2

Code compliant <>

Non-Compliant <>

2. All electrical in PVC conduit per NEC 300.5(4)

Code compliant <>

Non-Compliant <>

Approved for utilities placement <>

Inspector:

Date: