

#9

ROUGH IN PLUMBING

Permit #

Date:

Address:

Contractor:

COPY RIGHTS VILLAGE OF FOUR SEASONS

REVISED SEPTEMBER 2012

Building inspections verification points to comply with 2012 IRC

1. Verify gray water system only handles condensation from HVAC, discharge water from washing machine discharge from water softener and discharge form hot water relief valves. All plumbing for gray water must be designated by a non-white color piping.

Code compliant <> *Non-Compliant* <>

2. Vent piping must vent to the outdoors Per P3102.1

Code compliant <> *Non-Compliant* <>

3. Vent and branch vent pipes shall be graded connected and supported to allow moisture and condensate to drain back to the soil waste pipe by gravity Per P3104.2

Code compliant <> *Non-Compliant* <>

4. Air admittance valves must meet all code section P3114 1-8.

Code compliant <> *Non-Compliant* <>

5. Fixture traps per section P3201

Code Compliant <> *Non-Compliant* <>

6. Drilling and notching inspection Per P2603.2

Code compliant <> *Non-Compliant* <>

7. Water, soil or waste piping shall not be installed outside of a building, in exterior walls, in attics or crawl spaces or in any other place subject to freezing temperature unless adequate provision is made to protect it from freezing by insulation or heated or both per P2603.6

Code compliant <> *Non-Compliant* <>

8. The annular space between the outside of the pipe and the inside of the pipe sleeve or between the outside of a pipe and an opening in a building envelope wall, floor or ceiling assembly penetrated by a pipe shall be sealed with caulking material or foam sealant or closed with a gasketing system per P2606.1

Code Compliant <> Non-Compliant <>

9. Water Supply side of system to be tested at 50 psi Per P2503.6. All gas appliances will be tested Per G2417 (406)

Code compliant <> Non-Compliant <>

10. Piping shall be supported in accordance with P2605.1

Code compliant <> Non-Compliant <>

Comments _____

Approved <>

Inspector:

Date: