



Village of Four Seasons
133 Cherokee Road
Four Seasons, MO 65049
Phone: 573-365-3833 Ext.6
mac@villageoffourseasons.com

INSULATION INSPECTION

Building verification points to comply with 2018 IRC

ZONE RATING #4

1. R value per components in accordance with Table N1102.1.1
(R402.1.1)

Walls R19

Ceiling R49

Floor R19

2. Basement walls Per N1102.2.8 (R402.2.8)

3. Crawlspace walls per N1102.2.10 (R402.2.10)