



Village of Four Seasons
133 Cherokee Road
Four Seasons, MO 65049
Phone: 573-365-3833 Ext.6
mac@villageoffourseasons.com

UNDERGROUND UTILITIES

Building inspection verification points to comply with 2018 IRC and 2017 NEC codes.

1. Trench depth of 18 inches. Direct burial conductors and cables emerging from the ground shall be protected by enclosures or raceways extending from the minimum cover distance below grade requires by Section E3803.1 to a point at least 8 feet above finish grade per E3803.2
2. All electrical in PVC conduit per NEC 300.5(4)
3. *Warning tape. Underground service conductors that are not encased in concrete and are buried 18 inches or more below grade shall have their location identified by a warning ribbon that I placed in the trench not less than 12 inches above the underground installation per E3803.2*